



The undersigned, representative of the following manufacturer,

| Manufacturer and address | PITS N.V. Modular Lighting Instruments    |
|--------------------------|---|
|                          | Armoedestraat 71, 8800 Roeselare, BELGIUM |

Declares that the product

Product ID Product description

13516483 Tetrix Pinhole 62 LED 4000K medium GE black matt

Complies with the regulations of the following EC directives (including all applicable alterations):

| Reference no.                              | Title |
|--|-------|
| 2014/35/EU - Low Voltage Directive         |       |
| 2014/30/EU - EMC Directive                 |       |
| 2011/65/EU - RoHS Directive                |       |
| 2009/125/EC - ECOdesign Directive          |       |
|  |       |
| (EU) 2019/2020 and amendment (EU) 2021/341 |       |

Statement of (parts of) standards and/or technical specifications which have been applied for this declaration of conformity: Harmonized standards:

| Reference no.   | Title   |  |
|---|---|--|
| EN 60598-1:2015 + A1:2018 - Luminaires General Requirements And Tests   |   |  |
| EN 61547:2009 - EMC Immunity Requirements   |   |  |
| EN 62471:2008 - Photobiological Safety Of Lamps And Lan   | np Systems  |  |
|   |   |  |
|   |   |  |
| EN 60598-2-2:2012 - Recessed Luminaires   |   |  |
| EN 55015:2013 (incl ISH 1 & ISH 2) - Limits and methods of  | f measurement of radio disturbance characteristics of electrical lighting and similar equipment |  |
| EN 61000-3-2:2014 - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)  |   |  |
| EN 61000-3-3:2013 - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection |   |  |
| EN IEC 63000:2018 - Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances  |   |  |
|   |   |  |
|   |   |  |
|   |   |  |

And are produced under quality scheme at least in conformity with ISO9001 and ISO14001.

Place: ROESELARE, BELGIUM Bart Maeyens
Date: 02/11/2021 General Manager