



The undersigned, representative of the following manufacturer,

| Manufacturer and address | PITS N.V. Modular Lighting Instruments |
|--------------------------|---|
| | Armoedestraat 71, 8800 Roeselare, BELGIUM |

Declares that the product

Product ID Product description

13640109 Minude recessed trimless 49 1x LED 3000K medium GE white struc

Complies with the regulations of the following EC directives (including all applicable alterations):

| Reference no. | Title |
|--|-------|
| 2014/35/EU - Low Voltage Directive | |
| 2014/30/EU - EMC Directive | |
| 2011/65/EU - RoHS Directive | |
| 2009/125/EC - ECOdesign Directive | |
| | |
| (EU) 2019/2020 and amendment (EU) 2021/341 | |

Statement of (parts of) standards and/or technical specifications which have been applied for this declaration of conformity: Harmonized standards:

| Reference no. | Title | |
|---|---|--|
| EN 60598-1:2015 + A1:2018 - Luminaires General Requirements And Tests | | |
| EN 61547:2009 - EMC Immunity Requirements | | |
| EN 62471:2008 - Photobiological Safety Of Lamps And Lamp Systems | | |
| | | |
| EN 60598-2-1:1989 - Fixed General Purpose Luminaires | | |
| | | |
| 55015:2019 + A11:2020 (incl ISH 1 & ISH 2) - Limits and m | ethods of measurement of radio disturbance characteristics of electrical lighting and similar equipment | |
| EN 61000-3-2:2014 - Limits for harmonic current emissions (equipment input current ≤ 16 A per phase) | | |
| EN 61000-3-3:2013 - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current ≤ 16 A per phase and not subject to conditional connection | | |
| EN IEC 63000:2018 - Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances | | |
| | | |
| | | |
| | | |

And are produced under quality scheme at least in conformity with ISO9001 and ISO14001.

Place:ROESELARE, BELGIUMKristof VermeerschDate:28/02/2023General Manager