

Extruded suspension kit 2m surface GE

135231XX

1 CONNECT SUSP KIT WITH LED-MODULE

EXTRUDED SUSP KIT SURFACE INCLUDED

LED-MODULE NEEDS TO BE ORDERED SEPARATELY.

WEIGHT OF LIGHTING FIXTURE SHOULD ALWAYS BE CARRIED BY THE STEELCABLE!

1.1

1.2

1.3

2x

1.4

1.5

2x

3.1 LOOSEN THE SCREW

3.2 ADJUST STEELCABLE LENGTH

PUSH WHILE ADJUSTING CABLE

3.3 TIGHTEN THE SCREW

3.4 LOOSEN THE SCREWS

driver +
driver -

2x

3.5 ADJUST POWERCABLE LENGTH

3.6 TIGHTEN THE SCREWS

driver +
driver -

2x

4

INSTALL UNINSTALL

2

driver +
driver -

RED +
BLACK -

11mm
0.2 - 4mm²
24 - 12 AWG

≤ Ø4 mm
≤ Ø8 mm

Replace protective shield when broken. The luminaire shall only be used complete with its protective shield.
Reference number: 1014810

PREVENTING ELECTROSTATIC DAMAGE

A discharge of static electricity may damage sensitive components. Always be properly grounded when touching leads or circuitry inside the luminaire. Use a wrist strap connected by a ground cord to the housing. Avoid touching the light sources with bare hands.

DRIVERS & ACCESSORIES

For latest version of driver matrix and available accessories check www.supermodular.com or connect with your sales contact.